
Installation Instructions

Instrucciones de instalación, Instructions d'installation, Installationsanleitung, إر شادات التركيب , Installatie-instructies, Instruções de instalação, Installatie-instructies,

設置手順説明, Οδηγίες εγκατάστασης




Product Code: [ADDIM/30/MC]














Ansell Electrical Products Unit 6B, Stonecross Industrial Park, Yew Tree Way, Warrington,


Ansell (Sales & Distribution) Unit 2, M2 Business Park, Duncrue Street, Belfast. BT3 9AQ

Ansell (Sales & Distribution) Republic of Ireland Limited Unit G1, Block G, Calmount Park, Calmount Avenue Dublin 12. D12 TH56










(Spain Tel: 00 34 938 005642

WA3 3JD





SPECIFICATIONS

| 3F LCII ICATIONS | | | | | |
|-------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|--|--|
| Model | KL30C-PDiiV, 1x30W | | | | |
| Rated voltage | 220-240Vac, 50/60Hz | | | | |
| Rated current | 0.16A (max) | | | | |
| Operating temperature | -25°C~50°C | | | | |
| Dimming | DALI & PUSH & 0-10V | | | | |
| Output voltage | 300mA 9-58V DC 2.7-17W; 350mA 9-58V DC 3-20W; 400mA 9-58V DC 3.6-23W; 450mA 9-58V DC 4-26W; 500mA 9-58V DC 4.5-29W; 550mA 9-55V DC 5-30W; 600mA 9-50V DC 5.4-30W; 650mA 9-46V DC 5.8-30W; 700mA 9-42V DC 6.3-30W; 750mA 9-40V DC 6.7-30W; 800mA 9-38V DC 7.2-30W; 850mA 9-35V DC 7.6-30W; 900mA 9-34V DC 8.1-30W. | | | | |
| The wrie length of DALI | 300m Max. | | | | |
| Abnormal protection | Output short-circuit protection after restart | | | | |
| Overheating protection | Overheating protection after restart | | | | |
| EMC standard | EN55015, EN61000-3-2, EN61547, EN61000-3-3 | | | | |
| DALI standard | IEC62386-102, IEC62386-207 | | | | |
| Safety standard | EN61347-1 EN61347-2-13 | | | | |
| Certification | CE, ENEC14 | | | | |
| Dims | 103*67*22mm | | | | |
| Protection class | IP20 | | | | |
| | | | | | |

| | Output Current/Voltage Setting | | | | | | |
|---------|--------------------------------|----|----|----|----|--|--|
| ON 1 | | 1 | 2 | 3 | 4 | | |
| | 300mA | _ | ı | _ | _ | | |
| | 350mA | ON | - | _ | _ | | |
| | 400mA | _ | ON | _ | _ | | |
| | 450mA | ON | ON | _ | | | |
| | 500mA | _ | - | ON | _ | | |
| | 550mA | ON | _ | ON | _ | | |
| | 600mA | _ | ON | ON | _ | | |
| | 650mA | ON | ON | ON | _ | | |
| | 700mA | ON | ON | _ | ON | | |
| | 750mA | _ | _ | ON | ON | | |
| | 800mA | ON | _ | ON | ON | | |
| | 850mA | _ | ON | ON | ON | | |
| | 900mA | ON | ON | ON | ON | | |


Ansell Electrical Products Unit 6B, Stonecross Industrial

Park, Yew Tree Way, Warrington, WA3 3JD


Ansell (Sales & Distribution) Unit 2, M2 Business Park, Duncrue Street, Belfast, BT3 9AQ

Ansell (Sales & Distribution) Republic of Ireland Limited Unit G1, Block G, Calmount Park, Calmount Avenue Dublin 12, D12 TH56









(Spain Tel: 00 34 938 005642